

Overall

Module	Current/mA		Count			Σ KPD		Σ EX1/2		Σ OUT1-4		Comment
Integra 256 Plus	2000	3000	1	1	1	2000	3000	2000	3000	2000	3000	
	nom	max	KPD	EX1/2	OUT1-4	nom	max	nom	max	nom	max	
SP-4004 R	40	600			1	0	0	0	0	40	600	Battery load: 300mA; Alarm: 260mA
SP-4003 R	0.1	520			1	0	0	0	0	0.1	520	Alarm opt: 250mA; Alarm opt: 270mA
SPW-220 R	0.1	310			1	0	0	0	0	0.1	310	Alarm opt: 200mA; Alarm akk: 110mA
SPW-250 R	0.1	90			1	0	0	0	0	0.1	90	Alarm: 90mA
ETHM-1	70	80	1			70	80	0	0	0	0	
INT-TSI	500	620	1			500	620	0	0	0	0	
INT-TSG	250	265	2			500	530	0	0	0	0	
INT-KLCDS	33	151	1			33	151	0	0	0	0	
GSM LT-2	55	55	1			55	55	0	0	0	0	
INT-ADR	30	35		1		0	0	30	35	0	0	
ADR-MOD	1.2	1.2		48		0	0	57.6	57.6	0	0	not all in use yet
INT-KNX-2	43	50		1		0	0	43	50	0	0	
INT-PP	35	150		1		0	0	35	150	0	0	
INT-E	35	80		1		0	0	35	80	0	0	
INT-R	110	150		1		0	0	110	150	0	0	
CZ-EMM	50	50		1		0	0	50	50	0	0	
CZ-EMM4	80	80		1		0	0	80	80	0	0	
INT-RX-S	24	29		1		0	0	24	29	0	0	
INT-IORS	35	350		2		0	0	70	700	0	0	
OPAL Plus	15	20		1	1	0	0	15	20	15	20	
OPAL Pro	17	30		1	2	0	0	17	30	34	60	
Grey Plus	13	18			6	0	0	0	0	78	108	
FD-1	2.5	4			1	0	0	0	0	2.5	4	not connected yet
SUM	1894.4	4579.6				1158	1436	566.6	1431.6	169.8	1712	
Reserve	105.6						1564		1568.4		1288	